Bushfire Attack Level (BAL) Certificate

Determined in accordance with AS 3959-2018

This Certificate has been issued by a person accredited by Fire Protection Association Australia under the Bushfire Planning and Design (BPAD) Accreditation Scheme. The certificate details the conclusions of the full Bushfire Attack Level Assessment Report (full report) prepared by the Accredited Practitioner.

Property Details and Description of Works

Address Details	**Unit no**	**Street no**	**Lot no** 151	**Street name / Plan Reference** Capsico Grove		
	Suburb Wellard				**State** WA	**Postcode** 6170
Local government area	City of Kwinana					
Main BCA class of the building	1A	**Use(s) of the building**	Residence			
Description of the building or works	Residence					

Determination of Highest Bushfire Attack Level

AS 3959 Assessment Procedure	Vegetation Classification	Effective Slope	Separation Distance	BAL
Method 1	Class D Scrub	Flat land	> 60 m	BAL-12.5

BPAD Accredited Practitioner Details

Name
Sue Brand

Company Details
MBS Environmental

I hereby certify that I have undertaken the assessment of the above site and determined the Bushfire Attack Level stated above in accordance with the requirements of AS 3959:2018.

I hereby declare that I am a BPAD accredited bushfire practitioner.

Accreditation No. 36638

Signature

Date 16 May 2023

Authorised Practitioner Stamp

Reliance on the assessment and determination of the Bushfire Attack Level contained in this certificate should not extend beyond a period of 12 months from the date of issue of the certificate. If this certificate was issued more than 12 months ago, it is recommended that the validity of the determination be confirmed with the Accredited Practitioner and where required an updated certificate issued.